



Bureau Veritas
Consumer Products Services
Germany GmbH
Businesspark A96
86842 Türkheim
Germany
+ 49 (0) 40 740 41 – 0
cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH
Accredited according to EN 45011 -
ISO / IEC Guide 65

Certificate of compliance

Applicant: **PLATINUM GmbH**
Pfannerstr. 75
88239 Wangen i.A.
Germany

Product: **Integrated islanding prevention device between a generator and the public low-voltage grid**

Model: **PLATINUM 7000 R3-MDX-10; PLATINUM 9000 R3-MDX-10;**
PLATINUM 11000 R3-MDX-10; PLATINUM 14000 R3-MDX-10;
PLATINUM 16000 R3-MDX-10; PLATINUM 9000 R3-M2DXB;
PLATINUM 11000 R3-M2DXB; PLATINUM 14000 R3-M2DXB;
PLATINUM 16000 R3-M2DXB; PLATINUM 5500 R3-S2B;
PLATINUM 7000 R3-S2B; PLATINUM 8000 R3-S2B;
PLATINUM 9000 R3-S2B

Use in accordance with regulations:

Islanding prevention device in accordance with IEC 62116:2008 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The islanding prevention device is an integral part of the named inverters.

Applied rules and standards:

IEC 62116:2008

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: **12TH0029-IEC62116**

Certificate number: **U13-0821**

Date of issue: **2013-11-26**

Valid until: **2016-11-25**

